
550575 C

WIRING

CONNECTIONS Voltage Output:

Pin No. Wire Color Function Blue 0 to 10 Vdc (Note 1) Green Return for Pin 1 10 to 0 Vdc (Note 2) Yellow Orange Return for Pin 3 Red Customer Supplied Power (+ Vdc)* Black DC Ground Drain Wire Shield Drain Wire (Note 3) N/C N/C



8-Pin Integral or Hanging Connector (male profile) Connection Type 'C', 'H', or 'J'

Mating Accessories:

- P/N 251135 Field Installable Connector
- · Extension Cables

Current Output:

D: N/-	14/: 0-1	F attau
Pin No.	Wire Color	Function
1	Blue	4 to 20 mA, 0 to 20 mA
		20 to 4 mA, or 20 to 0 mA
2	Green	Return for Pin 1
3	Yellow	N/C
4	Orange	N/C
5	Red	Customer Supplied Power (+ Vdc)*
6	Black	DC Ground
7	Drain Wire	Shield Drain Wire (Note 3)
8	N/C	N/C

- * Power requirements are stroke length dependent.
- + 13.5 to 26.4 Vdc (± 0%): Stroke lengths ≤ 1525 mm (60 in.)
- + 24 Vdc (± 10%): Stroke lengths > 1525 mm (60 in.)

NOTES:

- Output = 0 Vdc when reference magnet is positioned at the electronics housing end of the sensor (forwardacting sensors).
- Output = 10 Vdc when reference magnet is positioned at the electronics housing end of the sensor (reverseacting sensors).
- 3. Shield drain wire should be isolated from DC ground (black wire) at the controller end of the cable.

Digital Output: (PWM or Start/Stop)

Pin No.	Wire Color	Function (PWM)
1	Blue	(-) Gate for PWM, (-) Stop for Start/Stop
2	Green	(+) Gate for PWM, (+) Stop for Start/Stop
3	Yellow	(-) Interrogation for PWM, (-) Start for Start/Stop
4	Orange	(+) Interrogation for PWM, (+) Start for Start/Stop
5	Red	Customer Supplied Power (+ Vdc)*
6	Black	DC Ground
7	Drain Wire	Shield Drain Wire (Note 3)
8	N/C	N/C

CONNECTIONS FOR 'G' STYLE MATING CABLES

RG Connector: (PWM or Start/Stop)

Pin No.	Wire Color	Function
1	Gray	(-) Gate for PWM, (-) Stop for Start/Stop
2	Pink	(+) Gate for PWM, (+) Stop for Start/Stop
3	Yellow	(+) Interrogation for PWM, (+) Start for Start/Stop
4	Green	(-) Interrogation for PWM, (-) Start for Start/Stop
5	Red or Brown	Customer Supplied Power (+ Vdc)*
6	White	DC Ground
7	-	No Connection


NOTES:

- 1. When wiring Temposonics L Series LP sensors equipped with a 'G' style connector, <u>do</u> <u>not</u> <u>connect DC ground</u> to the cable shield or drain wire.
- 2.) For single-ended interrogation, the unused interrogation lead must be connected to DC ground.
- 3.) When using PWM with internal interrogation, both interrogation leads must be connected to DC ground.
- 4.) Minimum load impedance for voltage outputs is 5K Ω .

RG Connector: (Voltage or Current Output)


į	Pin No.	Wire Color	Function
	1	Gray	0 to 10 Vdc
			4 to 20 mA or 0 to 20 mA
	2	Pink	Return for Pin 1
	3	Yellow	10 to 0 Vdc
			20 to 4 mA or 20 to 0 mA
	4	Green	Return for Pin 3
	5	Red or Brown	Customer Supplied Power (+ Vdc)*
	6	White	DC Ground
	7	-	No Connection

- * Power requirements are stroke length dependent.
- + 13.5 to 26.4 Vdc (± 0%): Stroke lengths ≤ 1525 mm (60 in.)
- + 24 Vdc (± 10%): Stroke lengths > 1525 mm (60 in.)




'G' Connector (Molded Mating Extension Cable Required)

TYPICAL 4-20 mA WIRING:








- page for detailed dimensional information.
- 2. Proper mounting and alignment of sensor is critical to ensure normal operation.

- 'C' Integral Connector w/Mating Connector: 114.3 mm (4.5 in.)
- 'H', 'J', 'L', and 'M' Integral Cables: 20 mm (0.8 in.)

MODEL NUMBER GUIDE



Iа	h	IΑ	Δ

E = External

Circulation Count vs. Resolution for

PWM Output (Based on 28 MHz counter)	
Resolution	Circulation Count*
0.00026	15
0.0005	8
0.001	4
0.002	2
0.004	1

^{*} Maximum circulation count is limited by stroke length for sensors configured for internal interrogation. (Refer to Table B for stroke length limitations.)

Table B


Maximum Stroke per Circulation Count for PWM Output w/Internal Interrogation

•
Circulation Count
15
4
2
1


PARAMETER	SPECIFICATION	
Measured Variable:	Displacement	
Resolution:	Analog: Infinite	
	Digital: 1 ÷ [gradient x crystal freq. (mHz) x circulation]; maximum resolution: 0.006 mm or 0.00025 in.	
Non-Linearity:	Captive Slide: ± 0.02% or ± 0.127 mm (0.005 in), whichever is greater	
-	Rod & Cylinder and Floating Magnet: ± 0.02% or ± 0.152 mm (0.006 in), whichever is greater	
Repeatability:	Equal to resolution	
Hysteresis:	< 0.02 mm (0.0008 inches)	
Outputs:	Analog: Voltage or Current; Digital: Start/Stop or PWM	
Measuring Range:	Analog: 25 to 2000 mm (1 to 78 in.); Digital: 25 to 3650 mm (1 to 144 in.)	
	[Rod & Cylinder version: max length = 1220 mm (48 in.)]	
Operating Voltage:	+ 13.5 to 26.4 Vdc (\pm 0%): Strokes \leq 1525 mm (60 in.); + 24 Vdc (\pm 10%): Strokes > 1525 mm (60 in.)	
Power Consumption:	100 mA	
Operating Temperature:	Head Electronics: - 40 to 70°C (- 40 to 158°F); Sensing Element: - 40 to 105°C (- 40 to 221°F)	
EMC Test:	DIN EN 50081-1 (Emissions);	
'G' style connector only) DIN EN 50082-2 (Immunity)		
Shock Rating: 100 g (single hit)/IEC standard 68-2-27 (survivability)		
Vibration Rating:	5 g/10-150 Hz/IEC standard 68-2-6	
Ipdate Time: Analog: < 1 ms; Digital: Minimum = [Stroke (specified in inches) + 3] x 9.1 μs		
Housing Style/Enclosure:	Dusing Style/Enclosure: Aluminum profile; drip, dust, and rust resistant; 'G' style connection meets IP 67 rating	
Magnet Type:	Floating magnet, captive sliding magnet, rod & cylinder	

The above specifications are assuming that output ripple is averaged by the measuring device as with any typical analog device. Specifications are subject to change without notice. Contact MTS to confirm specifications that are critical to your application.


ACCESSORIES



Mounting Feet



Threaded Rod End (P/N 560444)



Threaded Stud End (P/N 251975)

JAPAN

Ushikubo Bldg.

MTS Systems Corporation


Sensors Technologie, Japan

737 Aihara-cho, Machida-shi


Tokyo 194-0211, Japan

Phone: + 81 (42) 775.3838

Fax: + 81 (42) 775.5512



Captive Sliding Magnet (P/N 252092) for die cast applications



Captive Sliding Magnet (P/N 252052 & 252053)



SENSORS

Pioneers, Innovators, Leaders in Magnetostrictive Sensing UNITED STATES MTS Systems Corporation Sensors Division 3001 Sheldon Drive Cary, NC 27513 Tel: 800.633.7609 Fax: 919.677.0200

Fax: 919.677.0200 Email: info@temposonics.com Web: www.temposonics.com GERMANY
MTS Systems Corporation
Sensors Technologie

Auf dem Schuffel 9, D-58513 Lüdenscheid, Germany Postfach 8130 D-58489 Lüdenscheid, Germany Tel: + 49.2351.95870

Fax: + 49.2351.95870 Fax: + 49.2351.56491 Web: www.mtssensor.de







